

approval. This application must include a description of corrective actions taken, including results of completed performance testing as required for approval.

(vii) Any application or report submitted pursuant to paragraphs (b)(4)(i), (b)(4)(iii) and (b)(4)(vi) of this section must include a description of the performance testing completed for the simulation facility, and must include a description of performance tests, if different, to be conducted on the simulation facility during the subsequent four-year period, and a schedule for the conduct of approximately 25 percent of the performance tests per year for the subsequent four years.

(5) *Certification of simulation facilities.* Those facility licensees which propose, in accordance with paragraph (b)(1)(ii) of this section, to use a simulation facility consisting solely of a plant-referenced simulator as defined in § 55.4, shall—

(i) Submit a certification to the Commission that the simulation facility meets the Commission's regulations. The facility licensee shall provide this certification on Form NRC-474 in accordance with the schedule in paragraph (b)(2)(iii) or (b)(3)(iii) of this section, as applicable.

(ii) Submit, every four years on the anniversary of the certification, a report to the Commission which identifies any uncorrected performance test failures, and submit a schedule for correction of such performance test failures, if any.

(iii) Retain the results of the performance test conducted until four years after the submittal of certification under paragraph (b)(5)(i), each report pursuant to paragraph (b)(5)(ii), or recertification under paragraph (b)(5)(v) of this section, as applicable.

(iv) If the Commission determines, based upon the results of performance testing, that a certified simulation facility does not meet the requirements of this part, the simulation facility may not be used to conduct operating tests.

(v) If the Commission determines, pursuant to paragraph (b)(5)(iv) of this section, that a certified simulation facility does not meet the requirements of this part, the facility licensee may

submit a recertification to the Commission on Form NRC-474. This recertification must include a description of corrective actions taken, including results of completed performance testing as required for recertification.

(vi) Any certification report, or recertification submitted pursuant to paragraph (b)(5)(i), (b)(5)(ii) or (b)(5)(v) of this section must include a description of performance testing completed for the simulation facility, and must include a description of the performance tests, if different, to be conducted on the simulation facility during the subsequent four-year period, and a schedule for the conduct of approximately 25 percent of the performance tests per year for the subsequent four years.

[52 FR 9460, Mar. 25, 1987, as amended at 53 FR 43421, Oct. 27, 1988; 62 FR 59276, Nov. 3, 1997]

#### § 55.47 Waiver of examination and test requirements.

(a) On application, the Commission may waive any or all of the requirements for a written examination and operating test, if it finds that the applicant—

(1) Has had extensive actual operating experience at a comparable facility, as determined by the Commission, within two years before the date of application;

(2) Has discharged his or her responsibilities competently and safely and is capable of continuing to do so; and

(3) Has learned the operating procedures for and is qualified to operate competently and safely the facility designated in the application.

(b) The Commission may accept as proof of the applicant's past performance a certification of an authorized representative of the facility licensee or of a holder of an authorization by which the applicant was previously employed. The certification must contain a description of the applicant's operating experience, including an approximate number of hours the applicant operated the controls of the facility, the duties performed, and the extent of the applicant's responsibility.

## § 55.49

(c) The Commission may accept as proof of the applicant's current qualifications a certification of an authorized representative of the facility licensee or of a holder of an authorization where the applicant's services will be utilized.

### § 55.49 Integrity of examinations and tests.

Applicants, licensees, and facility licensees shall not engage in any activity that compromises the integrity of any application, test, or examination required by this part. The integrity of a test or examination is considered compromised if any activity, regardless of intent, affected, or, but for detection, would have affected the equitable and consistent administration of the test or examination. This includes activities related to the preparation and certification of license applications and all activities related to the preparation, administration, and grading of the tests and examinations required by this part.

[64 FR 19878, Apr. 23, 1999]

## Subpart F—Licenses

### § 55.51 Issuance of licenses.

*Operator and senior operator licenses.* If the Commission determines that an applicant for an operator license or a senior operator license meets the requirements of the Act and its regulations, it will issue a license in the form and containing any conditions and limitations it considers appropriate and necessary.

### § 55.53 Conditions of licenses.

Each license contains and is subject to the following conditions whether stated in the license or not:

(a) Neither the license nor any right under the license may be assigned or otherwise transferred.

(b) The license is limited to the facility for which it is issued.

(c) The license is limited to those controls of the facility specified in the license.

(d) The license is subject to, and the licensee shall observe, all applicable rules, regulations, and orders of the Commission.

## 10 CFR Ch. I (1–1–01 Edition)

(e) If a licensee has not been actively performing the functions of an operator or senior operator, the licensee may not resume activities authorized by a license issued under this part except as permitted by paragraph (f) of this section. To maintain active status, the licensee shall actively perform the functions of an operator or senior operator on a minimum of seven 8-hour or five 12-hour shifts per calendar quarter. For test and research reactors, the licensee shall actively perform the functions of an operator or senior operator for a minimum of four hours per calendar quarter.

(f) If paragraph (e) of this section is not met, before resumption of functions authorized by a license issued under this part, an authorized representative of the facility licensee shall certify the following:

(1) That the qualifications and status of the licensee are current and valid; and

(2) That the licensee has completed a minimum of 40 hours of shift functions under the direction of an operator or senior operator as appropriate and in the position to which the individual will be assigned. The 40 hours must have included a complete tour of the plant and all required shift turnover procedures. For senior operators limited to fuel handling under paragraph (c) of this section, one shift must have been completed. For test and research reactors, a minimum of six hours must have been completed.

(g) The licensee shall notify the Commission within 30 days about a conviction for a felony.

(h) The licensee shall complete a re-qualification program as described by § 55.59.

(i) The licensee shall have a biennial medical examination.

(j) The licensee shall not consume or ingest alcoholic beverages within the protected area of power reactors, or the controlled access area of non-power reactors. The licensee shall not use, possess, or sell any illegal drugs. The licensee shall not perform activities authorized by a license issued under this part while under the influence of alcohol or any prescription, over-the-counter, or illegal substance that could adversely affect his or her ability to